

School Name: Grand River Academy School Year: 2021-2022  
 First Day of School: 9/7/21 Last Day of School: 6/17/22  
 A **minimum of one Fire, Lockdown or Tornado drill must be conducted during lunch or recess.**

Fire Drills - three fire drills before Dec. 1 and two after Jan. 1 with reasonable spacing in between

Month	Date	Time	Notification Method	# of Staff Members	# Occupants Evacuated	Special Conditions Simulated	Problems Encountered	Weather Conditions	Min.	Sec.
Mar	3/8/22	1:00pm	Fire Bell	68	674		None	Cold	2	58
Nov	11/5/21	10:15AM	Alarm System	70	660	None	None	Clear	2	20
Sep	9/21/21	9:30am	Alarm	60	748	none	Noticed a bottleneck for two exits. We are working on a solution to reroute.	Clear	2	59
Apr	4/8/22	2:00pm	04/08/2022	60	633	none	student in hallway upset. Garza got him. Some classroom doors were open	Clear	2	8
Oct	10/21/21	1:30pm	Alarm	72	696	none	we noticed there is a large amount of students exiting through a specific exit as required. It is really slow this way.	Clear	3	10

**Room Clear** – One per school year, before December 1.

Date	Time	Special Conditions Simulated	Problems Encountered
10/26/21	9:30am	none	none

**Reverse Evacuation** – One per school year, after January 1.

Date	Time	Special Conditions Simulated	Problems Encountered
9/30/21	11:00AM		

**Lock Down** Three per school year. Two before Dec 1 and one after Jan 1.

Date	Time	Special Conditions Simulated	Problems Encountered
9/17/21	2:00pm		Staff in staff restroom can't hear drill; admin on radio giving all clear need to give their name so we know who has given the clear in their wings.
11/22/21	10:00 am	None	Kinder students in a couple of classes took long. Most of the building was ready within a minute.
10/18/21	1:45pm	Happened after a room clear situation	issues with the hallways where there are the ceiling glass where you can see outside. Need to figure a better place for students instead of those hallways. A kinder class didn't hear the announcement of the drill.

**Severe Weather/Tornado Drill** - Two per school year (one before Dec 15 and one in March)

Date	Time	Special Conditions Simulated	Problems Encountered
3/25/22	9:45am		We still have some issues with classes in the hallway where the ceiling glass is. We figured out some changes though.
10/8/21	1:45 PM	None	Art classroom left an interior, windowless room to go under the skylights. The two interior 4th grade classrooms left to go to the 3rd grade hallway.

**Reunification** – One type completed by **December 31**



Date	Time	Special Conditions Simulated	Problems Encountered
8/27/21	11:30am	none	Still need a site to operate in that is in a building.

**Signature of Person Responsible: Ralph Garza**